

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. LAB/ MDB /MAY /67

Dated: 22/05/2026

It is certified that an inspection team headed by Raman Kumar Jha Lab. Asst. (Name of Officers with designation) from PHED Madhubani


inspected the GREAT INDIA ACADEMY, TALIMABAD, MALMAL, KALUAHI DIST- MADHUBANI (BIHAR) PIN 847229.

(Name & Address of the school) on 21-05-2026 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no LAB/MAY/67 dated 22/05/2026 of Madhubani (PHED Lab)


certified that the GREAT INDIA ACADEMY (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 31.03.2027

Signature with Seal:  22/5/26

Name : ASRAF NAJMI

Designation : CHEMIST

Name & Address of the Office / Department : 

p

TO,
THE PRINCIPAL
GREAT INDIA ACADEMY
, TALIMABAD, MALMAL, KALUAHI
DIST- MADHUBANI (BIHAR) PIN
847229.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT LEVEL WATER TESTING LABORATORY

P.H.DIVISION, MADHUBANI

Sample Collected & Submitted Raman kr.jha Lab.Asst.

Sampling Date:- 21/05/2026

Testing Date:- 22/05/2026

Months:- May 2026

Sl No	Block	Panchayat	Village	Habitation	Source of Water	Name of Location/ Nearest Person	PH.	Tub.	T.H	T.A	Ca	Mg	Cl	Fe	F	TDS	EC	AS	Remarks
1.	KALUAHI	MALMAL	MALMAL	TALIMABAD	BORING	Great India Academy	7.4	1.8	130	200	26	9	20	0.3	0.1	172	254	NT	
Min-Max-Permissible Limit							6.5 - 8.5	1.0-05	200 - 600	200 - 600	75 - 200	30 - 100	250 - 1000	1.0	0.1 - 1.5	500 - 2000		0.01- NR	

*BDL- Below Detection Limit

*A - Absent

NOTE:- THIS TEST REPORT IS VALID FOR ONLY 4 MONTHS FROM THE DATE OF TESTING.

(Signature)
22.05.2026
Lab Assistant

District Level Laboratory, Madhubani

District Level Laboratory, Madhubani

(Signature)
22/05/2026
Chemist